

FIRE SAFETY CERTIFICATION

PRODUCT APPROVAL

No. **APF-1503**

LGAJ TECHNOLOGICAL CENTER S.A. (APPLUS), according to the requirements of the SPC-102 Ed. 5, certifies the performances stated in the technical annex following the reference standard for:

| | |
|--|---|
| Product model | F300/2 hours - RADIAL JET FAN ARMO-JR 50 60 Hz |
| Company | BAHÇIVAN ELEKTRİK MOTOR SAN. VE TİC LTD. STİ ÖMERLİ MAH. HADIMKÖY CD. No: 147 34555 ARNAVUTKÖY, İSTANBUL, TÜRKİYE |
| Manufactured | BAHÇIVAN ELEKTRİK MOTOR SAN. VE TİC LTD. STİ ÖMERLİ MAH. HADIMKÖY CD. No: 147 34555 ARNAVUTKÖY, İSTANBUL, TÜRKİYE |
| Standard Reference | EN 12101-3:2015 "Smoke and heat control systems. Part 3: Specification for powered smoke and heat control ventilators (fans)". |
| Product Details and Test Report | Please check at the technical annex file reports nº 19/17774-215 M1 and 20/23860-2428 |



Renovation of the initial certificate issued on 21th June 2019

Valid until 30th June 2022

Bellaterra, 19th July 2021

| | |
|---|---|
|  Applus⁺ LGAJ Technological Center, S.A. Xavier Ruiz Peña Product Conformity B. U., Managing Director |  |
| You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products | |

This document is not valid without its technical annex, whose number coincides with the number of certificate.